

Presentation Outline

- 1. Cornell University Energy Needs
- 2. Heat Demand in Eastern U.S.
- 3. Climate Action Plan
- 4. Current and Future Campus Energy Infrastructure
- 5. Lake-Source Cooling System
- 6. Combined Heat and Power Plant
- 7. Earth-Source Heat System


Cornell University Energy Statistics

- Main campus located in Ithaca, NY
- 33,000 student, faculty and staff
- 2018 Energy Needs:


| | Peak | Aver | Min |
|----------------------------------|------|------|-----|
| Electric (MW _e) | 35 | 22 | 20 |
| Heat (MW _t) | 90 | 28 | 8 |
| Chilled Water (MW _t) | 90 | 16 | 11 |




Campus heat demand concentrated in winter




Significant Heat Demand in Eastern U.S.




Cornell University targets climate neutrality by 2035 with Climate Action Plan




Steady Campus Energy Use Despite Campus Growth




Existing Cornell University Campus Energy Infrastructure



Existing Cornell University Campus Energy Infrastructure













Lake-Source District Cooling System

- Provides 98% of chilled water for campus
- Operates at COP of 25+
- Reduces summer electrical load by 10 MW_e
- Cold water extracted at 4°C at 76 m depth and reinjected around 11°C near surface
- Negligible thermal impact on Cayuga Lake











Combined Heat and Power (CHP) Plant

- Natural gas CHP commissioned in 2009
- 2 x 15 MW_e gas turbine generator sets
- Provides 90% of campus heating
- 2018: ~270,000 MWh of electricity and ~260,000 MWh of heating







Future Cornell University Campus Energy Infrastructure




Cornell University Earth-Source Heat Project


- Provide baseload heating to Ithaca campus
- Essential component for meeting carbon neutrality
- Demonstration project for Eastern U.S.
- Engage students, faculty, staff and local community in living laboratory project









Predicted temperatures in range 80-100°C in target reservoirs




Subsurface reservoir and surface equipment integration modeling

- Use of central heat pump
- System size on order of 10 MW_t
- LCOH's on order of \$6/MMBtu





Ongoing seismic and geophysical analyses








Engagement with local community through town hall meetings



Conclusions





Back-up Slides

Average Lake-Source Cooling Performance

